Newfoundland Labrador

BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: **Community Council of Port Au Port East**	MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): **WS-S-0572**
ADDRESS: **P.O. Box 160**	
Port Au Port	POSTAL CODE: **A0N 1T0** / TELEPHONE #: **648-2731**
SAMPLE COLLECTED BY: **Ryan Osmond**	DATE SAMPLE(S) COLLECTED: **April 23, 2025**
GSC LOCATION: **35 Alabama Drive, Stephenville, NL A2N 3K9**	

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS (Present, Absent or #/100ml)	FECAL COLIFORM (*E. coli*) (Present, Absent or #/100ml)	CHLORINE RESIDUAL (mg/L) Free Cl_2	CHLORINE RESIDUAL (mg/L) Total Cl_2	INTERPRETATION
1	Town Office	12:20	Absent	Absent	0.28	0.38	Satisfactory
2	Pumphouse	12:30	Absent	Absent	0.59		Satisfactory
	Fast trac Gas	12:40	Absent	Absent	0.04	0.16	Satisfactory
	32 romaines road	12:50	Absent	Absent	0.06	0.16	Satisfactory

REMARKS

Date Reported: (YY/MM/DD) 25-04-25	**David Janes, C.P.H.I.(C)** **Environmental Health Officer**

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPY VALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206	PORT AUX BASQUES	695-2835		