


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port	POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731	
SAMPLE COLLECTED BY: Ryan Osmond		DATE SAMPLE(S) COLLECTED: April 8, 2026	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS	FECAL COLIFORM (<i>E. coli</i>)	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
			(Present, Absent or #/100ml)	(Present, Absent or #/100ml)	Free Cl ₂	Total Cl ₂	
1	Pumphouse		Absent	Absent	0.58		Satisfactory
2	Fast Trac		Absent	Absent	0.39		Satisfactory
3	231 Main Rd		Not Tested	Not Tested	0.48		Improperly Labeled
4	TCO		Absent	Absent	0.68		Satisfactory

REMARKS

Satisfactory Results.	
Date Reported: (YY/MM/DD) 26-04-10	 David Janes, C.P.H.I.(C) Environmental Health Officer

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPY VALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206				