

July 20, 2023

Town of Port Au Port East
P.O. Box 160
Port Au Port NL A0N 1T0

**Subject: Boil Water Advisory
Town of Port au Port East**

This letter is a follow up to our telephone conversation on July 20, 2023 concerning the **removal of the Boil Water Advisory** for the Town of Port Au Port East.

Removal of the Boil Water Advisory is recommended at this time because the reason for issuing the advisory, *D1- Water distribution system is undergoing maintenance or repairs*, has been corrected and the following criteria have been met.

1. At least one satisfactory bacteriological water analysis was obtained (absent of total coliform and *E. coli* per 100ml of sample).
2. Satisfactory free chlorine residual is maintained at the entry to the distribution system.
3. Free chlorine residual is detectable & maintained throughout the distribution system.

Regular bacteriological monitoring of the public water supply will now commence on a monthly basis.

If you have any questions, please do not hesitate to give me a call at 637-2204/2369.

Sincerely yours,



David Janes, C.P.H.I.(C)
Environmental Health Officer

cc BWA Contacts