Newfoundland Labrador

BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: **Community Council of Port Au Port East**	MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): **WS-S-0572**	
ADDRESS: **P.O. Box 160**		
Port Au Port	POSTAL CODE: **A0N 1T0**	TELEPHONE #: **648-2731**
SAMPLE COLLECTED BY: **Ryan Osmond**	DATE SAMPLE(S) COLLECTED: **December 9, 2025**	
GSC LOCATION: **35 Alabama Drive, Stephenville, NL A2N 3K9**		

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS (Present, Absent or #/100ml)	FECAL COLIFORM (*E. coli*) (Present, Absent or #/100ml)	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
					Free Cl_2	Total Cl_2	
1	Western Petroleum	1:05	Absent	Absent	0.61		Satisfactory
2	Pumphouse	1:20	Absent	Absent	0.95		Satisfactory
	Town Office	1:10	Absent	Absent	0.52		Satisfactory
	29 Romaines road	1:30	Absent	Absent	0.62		Satisfactory

REMARKS

Date Reported: (YY/MM/DD) 25-12-12	**David Janes, C.P.H.I.(C)** **Environmental Health Officer** David Janes

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPYVALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206	PORT AUX BASQUES	695-2835		