


## BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: <b>Community Council of Port Au Port East</b>		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): <b>WS-S-0572</b>	
ADDRESS: <b>P.O. Box 160</b>			
<b>Port Au Port</b>		POSTAL CODE: <b>A0N 1T0</b>	TELEPHONE #: <b>648-2731</b>
SAMPLE COLLECTED BY: <b>Amanda Baker</b>		DATE SAMPLE(S) COLLECTED: <b>February 7, 2024</b>	
GSC LOCATION: <b>35 Alabama Drive, Stephenville, NL A2N 3K9</b>			

### WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS (Present, Absent or #/100ml)	FECAL COLIFORM (E. coli) (Present, Absent or #/100ml)	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
					Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	
1	Pumphouse		Absent	Absent	0.39	0.48	Satisfactory
2	Fast Trac		Absent	Absent	0.35	0.38	Satisfactory
3	32 Romaines Road		Absent	Absent	0.14	0.26	Satisfactory
4	54 Main Street		Absent	Absent	0.36	0.43	Satisfactory

### REMARKS

Satisfactory Results.	
Date Reported: (YY/MM/DD) 24-02-15	 <b>David Janes, C.P.H.I.(C)</b> Environmental Health Officer

#### Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPYVALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206				