


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port		POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731
SAMPLE COLLECTED BY: Ryan Osmond		DATE SAMPLE(S) COLLECTED: July 10, 2024	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small>	FECAL COLIFORM (<i>E. coli</i>) <small>(Present, Absent or #/100ml)</small>	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
					Free Cl ₂	Total Cl ₂	
1	Fastrac	12:00	Absent	Absent	0.03	0.18	Satisfactory
2	Pumphouse	12:10	Absent	Absent	0.45		Satisfactory
3	32 Romaine	12:20	Absent	Absent	0.02	0.04	Satisfactory
4	Town Office	11:50	Absent	Absent	0.18	0.39	Satisfactory

REMARKS

Date Reported: (YY/MM/DD) 24/07/12	David Janes, C.P.H.I.(C) Environmental Health Officer 

Service NL Centre Offices

ST. JOHN'S 729-2550	MARYSTOWN 279-0233	SPRINGDALE 673-4218	ST. ANTHONY 454-8833
HARBOUR GRACE 945-3107	GANDER 256-1420	CORNER BROOK 637-2204	HAPPY VALLEY/GOOSE BAY 896-2661
CLARENVILLE 466-4060	LEWISPORTE 535-0262	STEPHENVILLE 643-8650	
GRAND BANK 832-1672	GRAND FALLS-WINDSOR 292-4206	PORT AUX BASQUES 695-2835	