Newfoundland Labrador

BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		**MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable):** WS-S-0572
ADDRESS: P.O. Box 160		
Port Au Port	**POSTAL CODE:** A0N 1T0	**TELEPHONE #:** 648-2731
SAMPLE COLLECTED BY: Caden Brake	**DATE SAMPLE(S) COLLECTED:** July 28, 2025	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9		

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS (Present, Absent or #/100ml)	FECAL COLIFORM (*E. coli*) (Present, Absent or #/100ml)	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
					Free Cl_2	Total Cl_2	
1	Western Petroleum	12:55	Absent	Absent	0.23	0.27	Satisfactory
2	Pumphouse	1:02	Absent	Absent	0.65		Satisfactory
	54 Hynes Road	11:17	Absent	Absent	0.04	0.06	Satisfactory
	32 romaines road	1:13	Present	Absent	0.07	0.10	Repeat

REMARKS

Date Reported: (YY/MM/DD) 25-07-30	**David Janes, C.P.H.I.(C)** **Environmental Health Officer** David Janes

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPYVALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206	PORT AUX BASQUES	695-2835		