

BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East	MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): WS-S-0572	
ADDRESS: P.O. Box 160		
Port Au Port	POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731
SAMPLE COLLECTED BY: Amanda Baker	June 4, 2024	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9		

WATER SUPPLY RESULTS:

ID#	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS	FECAL COLIFORM (E. coli)	RESI	ORINE DUAL g/L)	INTERPRETATION
			(Present, Absent or #/100ml)	(Present, Absent or #/100ml)	Free Cl ₂	Total Cl₂	
1	Fastrac	11:55	Absent	Absent	0.14	0.24	Satisfactory
2	Pumphouse	12:10	Absent	Absent	0.35	0.41	Satisfactory
	32 Romaine	12:25	Absent	Absent	0.11	0.16	Satisfactory
	50 hynes road	11:45	Absent	Absent	0.06	0.09	Satisfactory

REMARKS		50
Date Reported: (YY/MM/DD) 24-06-05	David Janes, C.P.H.I.(C) Environmental Health Officer	Dava Vane

Service NL Centre Offices

ST. JOHN'S HARBOUR GRACE 729-2550 945-3107 MARYSTOWN

GANDER

279-0233 256-1420

SPRINGDALE

CORNER BROOK

673-4218 ST. ANTHONY 637-2204 HAPPY

454-8833 VALLEY/GOOSE

BAY

896-2661

CLARENVILLE **GRAND BANK**

466-4060 832-1672 LEWISPORTE

GRAND FALLS-WINDSOR

535-0262 292-4206 STEPHENVILLE

643-8650

PORT AUX BASQUES 695-2835