


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port		POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731
SAMPLE COLLECTED BY: Caden Brake		DATE SAMPLE(S) COLLECTED: June 9, 2025	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small>	FECAL COLIFORM (<i>E. coli</i>) <small>(Present, Absent or #/100ml)</small>	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
					Free Cl ₂	Total Cl ₂	
1	Western Petroleum	12:00	Absent	Absent	0.31	0.11	Satisfactory
2	Pumphouse	12:16	Absent	Absent	0.63		Satisfactory
	54 Hynes Road	12:08	Absent	Absent	0.44		Satisfactory
	32 romaines road	12:32	Absent	Absent	0.15	0.30	Satisfactory

REMARKS

Date Reported: (YY/MM/DD) 25-06-12	David Janes, C.P.H.I.(C) Environmental Health Officer 

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPYVALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206	PORT AUX BASQUES	695-2835		