


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port		POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731
SAMPLE COLLECTED BY: Nathan Christmas		DATE SAMPLE(S) COLLECTED: May 24, 2023	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small>	FECAL COLIFORM <i>(E. coli)</i> <small>(Present, Absent or #/100ml)</small>	CHLORINE RESIDUAL <small>(mg/L)</small>		INTERPRETATION
					Free Cl ₂	Total Cl ₂	
1	Pumphouse		Present	Absent	0.04	0.08	Unsatisfactory
2	Fast Trac		Absent	Absent	0.53		Satisfactory
3	32 Romaines Road		Absent	Absent	0.33		Satisfactory
4	53 Main Street		Absent	Absent	0.02	0.07	Satisfactory

REMARKS

Repeat Samples required.	
Date Reported: (YY/MM/DD) 23-05-31	 David Janes, C.P.H.I.(C) Environmental Health Officer

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPY VALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206				