


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port	POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731	
SAMPLE COLLECTED BY: David Janes		DATE SAMPLE(S) COLLECTED: October 30, 2024	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small>	FECAL COLIFORM <small>(E. coli)</small> <small>(Present, Absent or #/100ml)</small>	CHLORINE RESIDUAL <small>(mg/L)</small>		INTERPRETATION
					Free Cl ₂	Total Cl ₂	
1	Town Office	9:40	Absent	Absent	0.80		Satisfactory
2	Pumphouse	9:20	Absent	Absent	0.64		Satisfactory
	Post Office	9:30	Absent	Absent	0.10	0.12	Satisfactory
	40 Romaine's Road	10:25	Absent	Absent	0.04	0.05	Satisfactory

REMARKS

Date Reported: (YY/MM/DD) 24-11-04	David Janes, C.P.H.I.(C) Environmental Health Officer	
---------------------------------------	--	--

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPY VALLEY/GOOSE BAY	
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		896-2661
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206	PORT AUX BASQUES	695-2835		