


BACTERIOLOGICAL WATER ANALYSIS REPORT

| | | | |
|--|--|---|---------------------------------|
| WATER SYSTEM OWNER: Community Council of Port Au Port East | | MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): WS-S-0572 | |
| ADDRESS: P.O. Box 160 | | | |
| Port Au Port | | POSTAL CODE: A0N 1T0 | TELEPHONE #: 648-2731 |
| SAMPLE COLLECTED BY: Amanda Baker | | DATE SAMPLE(S) COLLECTED: October 1, 2024 | |
| GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9 | | | |

WATER SUPPLY RESULTS:

| ID # | SAMPLING SITES | TIME COLLECTED | TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small> | FECAL COLIFORM (<i>E. coli</i>) <small>(Present, Absent or #/100ml)</small> | CHLORINE RESIDUAL (mg/L) | | INTERPRETATION |
|------|------------------|----------------|--|---|-----------------------------|-----------------------|----------------|
| | | | | | Free Cl ₂ | Total Cl ₂ | |
| 1 | 73 Hynes road | 12:15 | Absent | Absent | 0.07 | 0.14 | Satisfactory |
| 2 | Fastrac | 12:25 | Absent | Absent | 0.48 | 0.53 | Satisfactory |
| | Pumphouse | 12:40 | Absent | Absent | 0.80 | 0.94 | Satisfactory |
| | 33 Romaines Road | 12:55 | Absent | Absent | 0.06 | 0.19 | Satisfactory |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

REMARKS

| | |
|---------------------------------------|--|
| | |
| | |
| | |
| | |
| | |
| | |
| Date Reported: (YY/MM/DD) 24-10-04 | David Janes, C.P.H.I.(C) Environmental Health Officer  |

Service NL Centre Offices

| | | | |
|------------------------|------------------------------|---------------------------|---------------------------------|
| ST. JOHN'S 729-2550 | MARYSTOWN 279-0233 | SPRINGDALE 673-4218 | ST. ANTHONY 454-8833 |
| HARBOUR GRACE 945-3107 | GANDER 256-1420 | CORNER BROOK 637-2204 | HAPPY VALLEY/GOOSE BAY 896-2661 |
| CLARENVILLE 466-4060 | LEWISPORTE 535-0262 | STEPHENVILLE 643-8650 | |
| GRAND BANK 832-1672 | GRAND FALLS-WINDSOR 292-4206 | PORT AUX BASQUES 695-2835 | |