

October 8, 2022

Town of Port Au Port East
P.O. Box 160
Port Au Port East NL
A0N 1T0

**Subject: Removal of Boil Water Advisory
Port Au Port East**

This letter is a follow up to our telephone conversation at on October 7, 2022 concerning the **removal of the Boil Water Advisory** for the public water supply of Town of Port Au Port East.

Removal of the Boil Water Advisory is recommended at this time because the reason for issuing the advisory: D(3)- Inadequately treated water was introduced into the system due to minor power outage.

1. At least two (2) successive satisfactory bacteriological water analysis are obtained (absent of total coliform and E. coli per 100ml of sample).
2. A satisfactory free chlorine residual is maintained at the entry to the distribution system.
3. A free chlorine residual is detectable & maintained throughout the distribution system.

Regular bacteriological monitoring of the public water supply will now commence on a monthly basis.

If you have any questions, please do not hesitate to give me a call at 637-2204/2369.

Sincerely yours,



David Janes, C.P.H.I.(C)
Environmental Health Officer

cc BWA Contacts


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port	POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731	
SAMPLE COLLECTED BY: Ryan Osmond		DATE SAMPLE(S) COLLECTED: Oct. 4, 2022	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small>	FECAL COLIFORM <small>(E. coli)</small> <small>(Present, Absent or #/100ml)</small>	CHLORINE RESIDUAL <small>(mg/L)</small>		INTERPRETATION
					Free Cl ₂	Total Cl ₂	
1	Bud's		Absent	Absent	1.22		Satisfactory
2	Fast Trac		Absent	Absent	0.77		Satisfactory
3	45 Hynes Rd		Absent	Absent	0.14	0.22	Satisfactory
4	32 Romaines Road		Absent	Absent	0.02	0.25	Satisfactory

REMARKS

Satisfactory Results.	
Date Reported: (YY/MM/DD) 22-10-08	 David Janes, C.P.H.I.(C) Environmental Health Officer

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPY VALLEY/GOOSE BAY 896-2661	
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206				


BACTERIOLOGICAL WATER ANALYSIS REPORT

WATER SYSTEM OWNER: Community Council of Port Au Port East		MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if, applicable): WS-S-0572	
ADDRESS: P.O. Box 160			
Port Au Port	POSTAL CODE: A0N 1T0	TELEPHONE #: 648-2731	
SAMPLE COLLECTED BY: Ryan Osmond		DATE SAMPLE(S) COLLECTED: Oct. 5, 2022	
GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9			

WATER SUPPLY RESULTS:

ID #	SAMPLING SITES	TIME COLLECTED	TOTAL COLIFORMS (Present, Absent or #/100ml)	FECAL COLIFORM (<i>E. coli</i>) (Present, Absent or #/100ml)	CHLORINE RESIDUAL (mg/L)		INTERPRETATION
					Free Cl ₂	Total Cl ₂	
1	Pumphouse		Absent	Absent	0.72		Satisfactory
2	Fast Trac		Absent	Absent	0.26	0.37	Satisfactory
3	45 Hynes Rd		Absent	Absent	0.19	0.29	Satisfactory
4	32 Romaines Road		Absent	Absent	0.10	0.16	Satisfactory

REMARKS

Satisfactory Results.	
Date Reported: (YY/MM/DD) 22-10-08	 David Janes, C.P.H.L.(C) Environmental Health Officer

Service NL Centre Offices

ST. JOHN'S	729-2550	MARYSTOWN	279-0233	SPRINGDALE	673-4218	ST. ANTHONY	454-8833
HARBOUR GRACE	945-3107	GANDER	256-1420	CORNER BROOK	637-2204	HAPPY VALLEY/GOOSE BAY	896-2661
CLARENVILLE	466-4060	LEWISPORTE	535-0262	STEPHENVILLE	643-8650		
GRAND BANK	832-1672	GRAND FALLS-WINDSOR	292-4206				