


BACTERIOLOGICAL WATER ANALYSIS REPORT

| | | | |
|--|--|--|---------------------------------|
| WATER SYSTEM OWNER: Community Council of Port Au Port East | | MUNICIPAL WATER SUPPLY REFERENCE NUMBER (if applicable): WS-S-0572 | |
| ADDRESS: P.O. Box 160 | | | |
| Port Au Port | | POSTAL CODE: A0N 1T0 | TELEPHONE #: 648-2731 |
| SAMPLE COLLECTED BY: Ryan Osmond | | DATE SAMPLE(S) COLLECTED: September 10, 2025 | |
| GSC LOCATION: 35 Alabama Drive, Stephenville, NL A2N 3K9 | | | |

WATER SUPPLY RESULTS:

| ID # | SAMPLING SITES | TIME COLLECTED | TOTAL COLIFORMS <small>(Present, Absent or #/100ml)</small> | FECAL COLIFORM (<i>E. coli</i>) <small>(Present, Absent or #/100ml)</small> | CHLORINE RESIDUAL (mg/L) | | INTERPRETATION |
|------|-------------------|----------------|--|---|-----------------------------|-----------------------|----------------|
| | | | | | Free Cl ₂ | Total Cl ₂ | |
| 1 | Western Petroleum | 11:50 | Absent | Absent | 0.26 | 0.38 | Satisfactory |
| 2 | Pumphouse | 12:10 | Absent | Absent | 0.68 | | Satisfactory |
| | Town Office | 11:40 | Absent | Absent | 0.58 | | Satisfactory |
| | 39 romaines road | 12:20 | Absent | Absent | 0.28 | 0.39 | Satisfactory |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

REMARKS

| | |
|--|--|
| | |
| | |
| Date Reported: (YY/MM/DD) 25-09-12 | David Janes, C.P.H.I.(C) Environmental Health Officer  |

Service NL Centre Offices

| | | | | | | | |
|---------------|----------|---------------------|----------|------------------|----------|-----------------------|----------|
| ST. JOHN'S | 729-2550 | MARYSTOWN | 279-0233 | SPRINGDALE | 673-4218 | ST. ANTHONY | 454-8833 |
| HARBOUR GRACE | 945-3107 | GANDER | 256-1420 | CORNER BROOK | 637-2204 | HAPPYVALLEY/GOOSE BAY | 896-2661 |
| CLARENVILLE | 466-4060 | LEWISPORTE | 535-0262 | STEPHENVILLE | 643-8650 | | |
| GRAND BANK | 832-1672 | GRAND FALLS-WINDSOR | 292-4206 | PORT AUX BASQUES | 695-2835 | | |